

CITY OF SHREVEPORT-PURCHASING DIVISION

P.O. BOX 31109 SHREVEPORT, LOUISIANA 71130-1109 Suite 610, 505 TRAVIS SHREVEPORT, LA 71101-3042
Phone 318/673-5450 web site: www.shreveportla.gov Fax 318/673-5408

June 9, 2023

ADDENDUM #3

IFB# 23-026

C.C. Antonine Park Improvements

Bidders on the Project are hereby notified that this addendum shall be attached to and made part of the above named solicitation documents dated May 12, 2023. The following items are issued to add to, to modify, and/or clarify the solicitation documents. These items shall have full force and effect as the solicitation documents. Bids, to be submitted on the specified bid date, shall conform to the additions and revisions listed herein. Acknowledge receipt of all addenda received by inserting the total number received on signature page of the bid form. Failure to do so may subject the bid to being declared as non-responsive.

It shall be the bidder's responsibility to make inquiry as to any addenda issued.

Questions

1.0 Question: The base bid includes food truck electrical service, pedestals, 2-pole lights, and pavilion lights and receptacles. Pavilion lights and receptacles are shown to be fed from bathroom panel LP, which is in Alternate No. 1?


Answer: All electrical facilities served from Panel LP shall be furnished and installed in Alternate No. 1. To clarify, the lighting and receptacles in the pavilion are not part of the base bid.

2.0 Question: In Alternate No. 2 includes spray park which shows no electrical service at all.

Answer: The spray park is hydraulically operated, and no power is to be supplied.

Continue to monitor BidSync and the City website www.shreveportla.gov/solicitations for any additional addenda. All questions must be submitted in writing. E-mail questions to Shay Meadows at dereka.abner-mims@shreveportla.gov

CITY OF SHREVEPORT



Renee Anderson, MBA, CPPB
Purchasing Agent