

# CITY OF SHREVEPORT-PURCHASING DIVISION

P.O. BOX 31109 SHREVEPORT, LOUISIANA 71130-1109 □ Suite 610, 505 TRAVIS SHREVEPORT, LA 71101-3042  
Phone 318/673-5450 web site: [www.shreveportla.gov](http://www.shreveportla.gov) Fax 318/673-5408

November 21, 2023

AMENDMENT #1

RFP 23-839

## Fuel Systems Repairs and Upgrades

Bidders on the Project are hereby notified that this Amendment shall be attached to and made part of the above-named solicitation documents dated October 25, 2023. The following items are issued to add to, to modify, and/or clarify the solicitation documents. These items shall have full force and effect as the solicitation documents. Proposals to be submitted on the specified bid date shall conform to the additions and revisions listed herein. Acknowledge receipt of all amendments received by inserting the total number received on signature page of the bid form. Failure to do so may subject the bid to being declared as non-responsive.

It shall be the Bidder's responsibility to make an inquiry as to any Amendments issued.

### Questions and Clarifications

1.0 Who is the manufacturer and what is the model of the existing automatic tank gauging system? I will need this information to determine what sensors and probes need to be included.

**According to City records, V/R – TLS 350; however as stated on the plans it shall be the responsibility of the Contractor to visit the job site prior to the bid date and to ascertain existing conditions. The job site is open during normal business hours; please email Angela McNicoll [angela.mcnicoll@shreveportla.gov](mailto:angela.mcnicoll@shreveportla.gov) prior to visiting the site so notifications can be made.**

2.0 What is the diameter of the existing USTs?

**According to City records, 126 inches on both tanks; however, as stated on the plans it shall be the responsibility of the Contractor to visit the job site prior to the bid date and to ascertain existing conditions. Please notify Angela McNicoll prior to visiting the site so notifications can be made.**

3.0 Is the existing Fuelmaster Plus card reader system to be reinstalled? If not, please specify the manufacturer and model of the new system requested.

**The existing card reader is to be reused.**

4.0 In lieu of the specified "Wayne Reliance, dual (2) product with pulser and hose mast hangers" we propose to provide and install 9153KSTW2 F Gasboy Atlas 22 gpm Max. 2-Hose 2-Product Mechanical Fleet Dispenser with Internal Filters with OPW 6102-1078P 78" Vertical Hose Retractors and Clamps. Will this substitution be acceptable?

**Please submit an electronic cover letter or transmittal sheet clearly identifying the RFP number and title and the proposed product information for review and approval.**

5.0 Is there a pre-bid site visit meeting scheduled for this work?


**No, there is not a pre-bid site visit, however you may make a visit to the site but contact Angela McNicoll prior to your visit.**

6.0 Are there any bonding requirements on this job? Several clauses say "when required" but I do not see anything showing required.

**Maintenance, performance, and payment bonds shall be required for this project.**

Please contact responsible buyer, Angela McNicoll, at (318) 673-5454, if you have any questions regarding this matter.

CITY OF SHREVEPORT



---

Renee Anderson, MBA, NIGP-CPP, CPPB  
Purchasing Agent